

## DC Interver Rooftop Package Up to 19 SEER



## **Features**

- Energy ratings as high as 19 SEER and can help lower your utility bills.
- DC inverter technology, by conventional thermostats.
- ECM outdoor&blower motors, High efficiency and more quiet.
- Horizontal or downflow application.
- Rotatable design for control board assembly, slide out design for blower motor (Easy for service).
- High efficiency heat exchanger.
- Convenient access panels, Single side service.
- Low sound levels.
- Universal curb, convenient installation and replacement.
- \* AHRI certified and ETL listed.







Reversing valve
Can be easily replaced

Convert design for horizontal and downflow

Convert design for horizontal and downflow

Indoor control board and optional heat strips

ECM blower motor can be easily slide out

Invert compressor

Out Control board with rotary design

## Specification-Heat pump

SaleModel			MRB-36HWD1N1-M19	MRB-60HWD1N1-M19
Powersupply		V-Ph-Hz	208/230V-1Ph-60Hz	208/230V-1Ph-60Hz
Cooling	Capacity	Btu/h	34800	57000
	SEER	Btu/h.W	18.5	19.0
	EER	Btu/h.W	12.0	12.5
Heating	Capacity	Btu/h	36000	57000
	HSPF	Btu/h.W	9.0	10.0
	Systempower	KW	2.88	4.56
Indoor fan motor	Туре		DC	DC
	Output	HP	1/2	3/4
Outdoor fan motor	Туре		DC	DC
	Output	HP	1/4	1/4
	RPM	r/min	950	880
Net Dimension (W*H *D)		mm	1286x891x1190	1310x1140x1306
		inch	50-11/16" x35-1/16" x46-13/16"	51-9/16" x 44-13/16" x 51-7/16"
Packing Dimension (W*H *D)		mm	1330×935×1239	1329x1155x1330
		inch	52-3/8" x36-13/16" x48-13/16"	52-3/8" x35-1/16" x45-7/16"
ESP range		in.WG	0-0.8	
Ambient temperature range	Cooling	-	23°F-125°F	
	Heating	-	-4°F-86°F	

Note: Specifications are subject to change without prior notice for product improvement.

## Midea Building Technologies Division

**Midea Group** 

Add.: Midea Headquarters Building, 6 Midea Avenue, Shunde, Foshan, Guangdong, China

Postal code: 528311

hbt.midea.com www.midea-group.com







Note: Product specifications change from time to time as product improvements and developments are released and may vary from those in this document.