


50NPB
Single-Packaged Air Conditioner System
with Puron Advance™ (R-454B) Refrigerant
Single Phase
2 to 5 Nominal Tons (Sizes 024-060)




Turn to the experts

Product Data



50NPB 024-048

A10165



50NPB 060

A150067

Fig. 1 – Unit 50NPB

Features/Benefits

This unit is a packaged air conditioner for manufactured housing, residential, and light commercial applications. The unit design is the result of our firm commitment to the development of the finest air conditioners that modern technology can offer.

The unit is built in one basic cabinet size and features a round or rectangular side-by-side duct configuration.

R-454B is the latest choice of refrigerant to help meet the 2025 GWP requirement. This unit is designed and tested with R-454B and contains a dissipation system.

FACTORY-ASSEMBLED PACKAGE is a compact, fully self-contained, electric cooling unit with horizontal supply and return ducts. The unit is available in a variety of standard cooling sizes to meet residential and light commercial requirements. Unit installs easily on a ground level pad.

EASY TO INSTALL - The unit is small, compact, and easy to handle. Every unit has an identical 32 x 51-in. (813 x 1295 mm) footprint to make planning simple. The concise design uses less sheet metal and

makes the unit lighter than other units. The unit can be easily positioned on the job site with the hand holds built into the unit basepan.

AERODYNAMIC FAN BLADE DESIGN reduces the overall sound now as low as 70dBA.

SERVICE ACCESS makes installation and maintenance quicker and easier. This unit is designed to be serviced from both the side and front. The design allows easy access for installation and maintenance procedures on the unit. Routine maintenance tasks such as coil cleaning are sped up with the multiple access side panels.

NO-RUST BASEPAN WITH INTEGRATED DRAIN PAN is standard on all units. The unit features a tough, hightech, composite material basepan with integrated drain pan. The composite material eliminates the potential problems of rust and premature replacement which are common with standard metal basepans.

DURABLE PRE-PAINTED STEEL CABINET protects against harsh weather. The watertight construction and corrosion-resistant finish will keep it looking like new for years. The paint treatment process ensures quality protection against the elements. A compact, low-profile design utilizes a louvered coil enclosure for protection against vandalism and hail damage.

INDOOR AIR QUALITY is designed into the unit. A sloped drain pan minimizes the amount of standing water inside the unit, which limits mold and mildew growth. The drain pan is made of a rust-proof material and will not deteriorate or release foreign matter into the airstream.

LIGHTWEIGHT, COMPACT CONSTRUCTION is ideal for manufactured housing and residential applications. This unit is one of the lightest, most compact packaged units ever designed. It's light weight (244 lb [111 kg] for the 024 size) makes the unit easier to handle. The low height keeps ductwork connections to a minimum and makes units less visible.

This unit utilizes a structural beam design to form the four sides of the cabinet. Only 12 different pieces of sheet metal are used in the unit construction to simplify the unit for greater reliability.

EFFICIENT, DEPENDABLE PERFORMANCE with durable compressors designed for efficiency. The unit offers up to 13.4 SEER2 (Seasonal Energy Efficiency Ratio) cooling performance efficiencies. This performance level can reduce cooling expenses by as much as 30% compared to older cooling equipment.

DURABLE, DEPENDABLE, COMPRESSORS are designed for high efficiency. Each compressor is hermetically sealed against contamination to help promote longer life and dependable operation. Vibration isolation provides quiet operation. Compressors have internal overcurrent protection.

DIRECT-DRIVE MULTISPEED, BLOWER MOTOR is standard on all models. It's high efficiency design ensures high performance with most duct systems.

DIRECT-DRIVE, PSC CONDENSER-FAN MOTORS are designed to help reduce energy consumption and provide for cooling operation down to 40°F (4.4°C).

REFRIGERANT SYSTEM is designed to provide dependability. Liquid refrigerant filter driers are used to promote clean, unrestricted operation. Each unit leaves the factory with non-ozone depleting and low global warming potential R-454B refrigerant charge. Refrigerant service connections make checking operating pressures easier. Factory-installed leak detection dissipation system for added safety.

AIR HANDLING LEAKAGE — Cabinet air leakage less than 2.0% at 1.0 in. W.C. and cabinet air leakage less than 1.4% at 0.5 in W.C. when tested in accordance with ASHRAE standard 193

ACCESSORY ELECTRIC HEATERS — A variety of accessory electric heaters are available. These heaters are comprised of a separate heater module mounted on the blower inlet and remote mounted controls located in the unit control box. Single point electrical connections are available for powering both the heater and the unit.

Limited Warranty*


- Default 5 year parts limited warranty
 - 10 year parts limited warranty with timely registration. Equipment must be registered within 90 days of original installation, except in jurisdictions where warranty benefits cannot be conditioned on registration.
- * Applies to original purchaser/homeowner and 5 years to subsequent owners.
- Default 5 year on compressor limited warranty
 - 10-year on compressor limited warranty with timely registration. Equipment must be registered within 90 days of original installation, except in jurisdictions where warranty benefits cannot be conditioned on registration.
- * Applies to original purchaser/homeowner and 5 years to subsequent owners. See warranty certificate for complete details and restrictions

Table of Contents

Features/Benefits	1
Model Nomenclature	2
AHRI Capacity Ratings	3
A-Weighted Sound Power Level (dBA)	3
Physical Data	3
Accessories	4
Dimensional Drawing	5
Dimensional Drawings	6
Dimensional Drawings	7

Selection Procedure	8
Wet Coil Air Delivery	13
Typical Connection Wiring Schematic	14
Electrical Data	17
Operating Sequence	17
Application Data	18
Guide Specifications	19

Model Nomenclature



Use of the AHRI Certified TM Mark indicates a manufacturer's participation in the program. For verification of certification for individual products, go to www.ahridirectory.org.



SAP ORDERING NO.	NOMINAL COOLING CAPACITY (Btuh)	VOLTS-PHASE (60 HZ)	APPROX SHIP WT (LB)
50NPB024---30	24,000	208/230-1-60	294
50NPB030---30	30,000	208/230-1-60	299
50NPB036---30	36,000	208/230-1-60	318
50NPB042---30	42,000	208/230-1-60	342
50NPB048---30	48,000	208/230-1-60	394
50NPB060---30	60,000	208/230-1-60	409

AHRI* Capacity Ratings

Cooling Capacities and Efficiencies

UNIT SIZE	NOMINAL TONS	STANDARD CFM	Ratings in accordance with U.S. Government DOE (Department of Energy) Appendix M1 test procedures and/or AHRI Standards 210/240		
			NET COOLING CAPACITY (Btuh) [†]	EER2 [†]	SEER2
24	2	800	23,000	11.05	13.4
30	2.5	1000	28,600	11.05	13.4
36	3	1200	33,400	11.05	13.4
42	3.5	1400	41,000	11.05	13.4
48	4	1600	47,000	11.05	13.4
60	5	1850	54,500	11.05	13.4

*. Air Conditioning Heating & Refrigeration Institute

†. At "A" conditions -- 80°F (26.7°C) indoor db / 67°F (19.4°C) indoor wb & 95°F (35°C) outdoor db.

Notes:

1. Ratings are net values, reflecting the effects of circulating fan heat.
2. Before purchasing this appliance, read important energy cost and efficiency information available from your retailer.

A-Weighted Sound Power Level (dBA)

UNIT SIZE	STANDARD RATING (dBA)	TYPICAL OCTAVE BAND SPECTRUM (dBA without tone adjustment)						
		125	250	500	1000	2000	4000	8000
24	70	56	60	63	67	59	53	44
30	70	60	61	63	65	60	56	50
36	76	63	67	70	72	65	60	53
42	77	65	70	72	72	67	62	53
48	78	65	69	72	74	68	63	53
60	80	67	69	74	76	73	67	59

NOTE: Tested in compliance with AHRI 270 but not listed with AHRI.

Physical Data

UNIT SIZE	024	030	036	042	048	060
NOMINAL CAPACITY (ton)	2	2.5	3	3.5	4	5
SHIPPING WEIGHT (lb)	294	299	318	342	394	409
(kg)	133	136	144	155	179	186
COMPRESSOR TYPE	SCROLL					
REFRIGERANT	R-454B					
REFRIGERANT QUANTITY (lb)	3.00	3.50	4.44	4.60	5.00	7.00
(kg)	1.36	1.59	2.01	2.09	2.27	3.18
METERING DEVICE ID	TXV	Piston				TXV
ORIFICE OD (in.)		.061	.063	.067	.078	
(mm)	N/A	1.55	1.60	1.70	1.98	N/A
MINIMUM CONDITIONED SPACE AREA (sq. ft)	61	61	76	76	76	106
OUTDOOR COIL ROWS...FINS/in.	1...20	1...20	2...20	2...20	2...20	2...20
FACE AREA (sq. ft)	9.1	9.1	9.1	10.2	13.0	15.5
OUTDOOR FAN NOMINAL AIRFLOW (CFM)	2400	2400	2700	2700	2700	3000
DIAMETER (in.)	20	20	20	20	20	20
DIAMETER (mm)	508	508	508	508	508	508
MOTOR HP (RPM)	1/8 (825)	1/8 (825)	1/4 (1100)	1/4 (1100)	1/4 (1100)	1/3 (1110)
REQUIRED MINIMUM DISSIPATION AIRFLOW (CFM)	133	133	133	133	133	186
INDOOR COIL ROWS...FINS/in.	2...12	3...15	3...12	3...12	3...15	3...15
FACE AREA (sq. ft)	4.3	4.3	4.3	4.9	4.9	6.1
INDOOR BLOWER NOMINAL COOLING AIRFLOW (CFM)	800	1000	1200	1400	1600	1850
NOMINAL SIZE W x D (in.)	8 x 11	8 x 11	9 x 12	9 x 12	11 x 12	11 x 12
(mm)	254 x 203	254 x 203	279 x 229	279 x 229	279 x 229	267 x 305
MOTOR (HP)	1/3	1/2	1/2	1/2	3/4	1
HIGH-PRESSURE SWITCH (psig)						
CUTOUT	650 +/- 15					
RESET (AUTO)	420 +/- 25					
RETURN-AIR FILTERS*						
THROWAWAY (in.)	20x20x1	20x24x1	24x30x1	24x36x1		
(mm)	508x508x25	508x610x25	610x762x25	610x914x25		

*. *Required filter sizes shown are based on the AHRI (Air Conditioning, Heating and Refrigeration Institute) rated airflow at a velocity of 300 ft/min for throwaway type or 450 ft/min for high capacity type. Recommended filters are 1-in. (25.4 mm) thick.

Accessories

DESCRIPTION	USED WITH	PART NUMBER
Low Ambient Control	All	CPLOWAMB001A00
Compressor Start Kit	All	CPHSTART002A00
240V Crankcase Heater	024-042	CPCRKHTR008A00
	048-060	CPCRKHTR004A00

Accessory Electric Heaters

✓=Approved combination

Multiplication Factors


HEATER kW RATING	VOLTAGE DISTRIBUTION	MULTIPLICATION FACTOR
240	200	.69
	208	.75
	230	.92
	240	1.00

Example: 15.0 kW (at 240v) heater on 208v
 = 15.0 (.75 mult factor)
 = 11.25 capacity at 208v

Dimensional Drawing

024-036

COOLING CAPACITY	UNIT WT. LBS. / KG.	UNIT HEIGHT IN. / MM.	X IN. / MM.	Y IN. / MM.	Z IN. / MM.
24	511 232	30-1/8 [765]	14 [356]	19 [483]	14 [356]
30	511 232	30-1/8 [765]	14 [356]	19 [483]	14 [356]
36	511 232	30-1/8 [765]	14 [356]	19 [483]	14 [356]



REQUIRED CLEARANCES TO COMBUSTIBLE MATL.

INCHES (MM)

TOP OF UNIT.....0

BOTTOM OF UNIT.....0

SIDE OF UNIT WITH DUCT OPENINGS.....0

SIDE OF UNIT OPPOSITE DUCT OPENINGS.....0

NEC REQUIRED CLEARANCES.

INCHES (MM)

BETWEEN UNITS, POWER ENTRY SIDE.....42.0 [1067]

UNIT AND BLOCK OR CONCRETE WALLS AND OTHER GROUNDED SURFACES, POWER ENTRY SIDE.....42.0 [1067]

REQUIRED CLEARANCE FOR SERVICING


INCHES (MM)

TOP OF UNIT, OPPOSITE DUCT OPENINGS.....36.0 [914]

SIDE OF UNIT WITH POWER ENTRY (EXCEPT FOR NEC REQUIREMENTS).....36.0 [914]

NOTE: CLEARANCES MUST BE MAINTAINED TO PREVENT RECIRCULATION OF AIR FROM OUTDOOR FAN DISCHARGE. A REMOVABLE FENCE OR BARRICADE REQUIRES NO CLEARANCE.

DIMENSIONS IN () ARE IN MM




U.S. EXPORT CLASSIFICATION: NOT SUBJECT TO REGULATION (NSR)

SD6006-4	-
----------	---

Dimensional Drawings

042-048

COOLING CAPACITY		UNIT WT.	UNIT HEIGHT	CENTER OF GRAVITY IN (MM)		
LES.	KG.	A		X	Y	Z
292	132	34-1/8 (867)		14 (356)	19 (483)	16 (406)
344	156	42-7/8 (1070)		14 (356)	19 (483)	19-3/4 (503)



TOP VIEW

REQUIRED CLEARANCES TO COMBUSTIBLE MATL.

	INCHES (MM)
TOP OF UNIT.....	0
BOTTOM OF UNIT.....	0
SIDE OF UNIT WITH DUCT OPENINGS.....	0
SIDE OF UNIT OPPOSITE DUCT OPENINGS.....	0

NEC REQUIRED CLEARANCES


	INCHES (MM)
BETWEEN UNITS, POWER ENTRY SIDE.....	42.0 (1067)
UNIT AND UNGROUNDED SURFACES, POWER ENTRY SIDE.....	36.0 (914)
UNIT AND BLOCK OR CONCRETE WALLS AND OTHER GROUNDED SURFACES, POWER ENTRY SIDE.....	42.0 (1067)

REQUIRED CLEARANCE FOR SERVICING

	INCHES (MM)
TOP OF UNIT.....	0
SIDE OF UNIT OPPOSITE DUCT OPENINGS.....	30.0 (762)
SIDE OF UNIT WITH POWER ENTRY (EXCEPT FOR NEC REQUIREMENTS).....	30.0 (762)

NOTE: CLEARANCES MUST BE MAINTAINED TO PREVENT RECIRCULATION OF AIR FROM OUTDOOR FAN DISCHARGE. A REMOVABLE FENCE OR BARRICADE REQUIRES NO CLEARANCE.

DIMENSIONS IN () ARE IN MM



LEFT SIDE VIEW

FRONT VIEW

RIGHT SIDE VIEW

REAR VIEW

U.S. EXPORT CLASSIFICATION: NOT SUBJECT TO REGULATION (MSR)

SD6006-4

Selection Procedure

DETERMINE COOLING AND HEATING REQUIREMENTS AT DESIGN CONDITIONS.

Given:

Required Cooling Capacity (TC).....	33,000 Btuh
Sensible Heat Capacity (SHC).....	25,000 Btuh
Required Heating Capacity	15,000 Btuh
Outdoor Entering-Air Temperature.....	95°F (35°C)
Indoor Entering-Air Temperature	80°F edb (26.7°C); 67°F (19.4°C) ewb
Indoor-Air Quantity	1200 CFM
External Static Pressure	0.20 IN. W.C.
Electrical Characteristics (V-Ph-Hz).....	230-1-60
Filter Size	20x24x1-in.
edb - Entering Dry Bulb	
CFM - Cubic Feet per Minute	

SELECT UNIT BASED ON REQUIRED COOLING CAPACITY (3-TON EXAMPLE)

Enter Cooling Capacities table at condenser entering temperature of 95°F (35°C), indoor air entering at 1200 CFM and 67°F (19.4°C) ewb. The 036 unit provides a total cooling capacity of 33,500 Btuh and a sensible heat capacity of 25,800 Btuh.

For indoor-air temperature other than 80°F (26.7°C) edb, calculate sensible heat capacity correction, as required, using the formula found following the Cooling Capacities tables.

NOTE: Unit ratings are net capacities.

SELECT ELECTRIC HEAT

The required heating capacity is 15,000 Btuh (given).
Determine the electric heat capacity in kW.

$$\frac{15,000 \text{ Btuh}}{3414 \text{ Btuh/kW}} = 3.8 \text{ kW of heat required}$$

Enter the Accessory Electric Heater table on page 4 for 208/230, single-phase, 036 unit. The 5-kW heater at 240v most closely satisfies the heating required. To calculate kW at 230 V, multiply the heater kW by multiplication factor 0.92 found in the Multiplication Factors table on page 4.

$$5 \text{ kW} \times 0.92 = 4.6 \text{ kW}$$

$$4.6 \text{ kW} \times 3414 \text{ Btuh/kW} = 15,704 \text{ Btuh}$$

DETERMINE FAN SPEED AND POWER REQUIREMENTS AT DESIGN CONDITIONS.

Before entering the air delivery tables, calculate the total static pressure required. From the given, Filter Pressure Drop table, and the Accessory Electric Heat Pressure Drop table find:

External static pressure	0.20 IN. W.C.
Filter	0.13 IN. W.C.
Electric Heat	<u>0.04 IN. W.C.</u>
Total static pressure	0.37 IN. W.C.

Enter the table for Dry Coil Air Delivery — Horizontal Discharge. At 0.4 IN. W.C. external static pressure and red speed, the motor delivers 1290 CFM.

Performance Data
Cooling Capacities
024

EVAPORATOR AIR		CONDENSER ENTERING AIR TEMPERATURES °F (°C)																	
		75 (23.9)			85 (29.4)			95 (35)			105 (40.6)			115 (46.1)			125 (51.7)		
		Capacity MBtuh		Total System KW**	Capacity MBtuh		Total System KW**	Capacity MBtuh		Total System KW**	Capacity MBtuh		Total System KW**	Capacity MBtuh		Total System KW**	Capacity MBtuh		Total System KW**
CFM	EWB	Total	Sens†		Total	Sens†		Total	Sens†		Total	Sens†		Total	Sens†		Total	Sens†	
700	57 (13.9)	22.2	22.2	1.6	21.5	21.5	1.8	20.4	20.4	2.0	17.8	17.8	2.2	15.6	15.6	2.4	13.2	13.2	2.7
	62 (16.7)	23.1	21.3	1.6	22.0	20.7	1.8	21.0	19.6	2.0	18.3	17.4	2.2	16.0	15.8	2.4	13.5	13.3	2.7
	63 (17.2)††	23.5	17.1	1.6	22.5	16.6	1.8	21.2	16.0	2.0	18.3	14.7	2.2	15.8	14.1	2.4	13.0	12.7	2.7
	67 (19.4)	25.3	17.9	1.6	24.2	17.3	1.8	22.8	16.7	2.0	20.3	15.4	2.2	17.8	14.7	2.4	14.8	13.2	2.7
	72 (22.2)	27.6	14.3	1.7	26.4	13.7	1.8	24.9	13.1	2.0	21.5	12.0	2.2	18.7	11.3	2.5	15.4	10.0	2.8
800	57 (13.9)	23.3	23.0	1.7	22.5	21.7	1.8	21.4	20.4	2.0	18.7	18.0	2.3	16.4	16.4	2.5	13.8	13.8	2.8
	62 (16.7)	23.6	22.1	1.7	22.5	21.5	1.8	21.5	20.4	2.0	18.7	18.0	2.3	16.4	16.4	2.5	13.8	13.8	2.8
	63 (17.2)††	23.8	17.8	1.7	22.7	17.2	1.8	21.5	16.7	2.0	18.5	15.3	2.3	16.0	14.7	2.5	13.2	13.2	2.8
	67 (19.4)	25.6	18.6	1.7	24.5	18.0	1.8	23.1	17.3	2.0	20.5	16.0	2.3	18.0	15.3	2.5	15.0	13.7	2.8
	72 (22.2)	27.9	14.8	1.7	26.7	14.2	1.8	25.2	13.7	2.1	21.8	12.4	2.3	18.9	11.8	2.5	15.6	10.4	2.8
900	57 (13.9)	24.1	24.1	1.7	23.3	23.2	1.8	22.2	21.8	2.0	19.3	19.3	2.3	16.9	16.9	2.5	14.3	14.3	2.8
	62 (16.7)	24.4	23.9	1.7	23.3	23.0	1.8	22.2	21.8	2.0	19.3	19.3	2.3	16.9	16.9	2.5	14.3	14.3	2.8
	63 (17.2)††	24.6	19.0	1.7	23.5	18.4	1.8	22.2	17.8	2.0	19.1	16.4	2.3	16.6	15.7	2.5	13.7	13.7	2.8
	67 (19.4)	26.5	19.8	1.7	25.3	19.2	1.9	23.9	18.5	2.1	21.3	17.1	2.3	18.6	16.3	2.5	15.5	14.6	2.8
	72 (22.2)	28.9	15.9	1.7	27.6	15.2	1.9	26.1	14.6	2.1	22.5	13.3	2.3	19.6	12.6	2.5	16.1	11.1	2.8

See Legend and Notes on page 12.

030

EVAPORATOR AIR		CONDENSER ENTERING AIR TEMPERATURES °F (°C)																	

Cooling Capacities (cont)
036

EVAPORATOR AIR		CONDENSER ENTERING AIR TEMPERATURES °F (°C)																	
CFM	EWB	75 (23.9)			85 (29.4)			95 (35)			105 (40.6)			115 (46.1)			125 (51.7)		
		Capacity MBtuh		Total System KW**	Capacity MBtuh		Total System KW**	Capacity MBtuh		Total System KW**	Capacity MBtuh		Total System KW**	Capacity MBtuh		Total System KW**	Capacity MBtuh		Total System KW**
		Total	Sens‡		Total	Sens‡		Total	Sens‡		Total	Sens‡		Total	Sens‡		Total	Sens‡	
1050	57 (13.9)	31.6	31.6	2.2	31.1	31.1	2.5	29.6	29.6	2.7	25.6	25.6	3.0	23.5	23.5	3.3	21.5	21.5	3.6
	62 (16.7)	32.9	30.5	2.2	32.0	30.9	2.5	30.5	29.2	2.7	26.3	25.8	3.0	24.2	23.8	3.3	22.1	21.7	3.6
	63 (17.2)††	33.5	24.6	2.2	32.6	24.7	2.5	30.8	23.9	2.7	26.2	22.4	3.0	23.9	22.0	3.3	21.3	20.7	3.6
	67 (19.4)	36.1	25.6	2.3	35.1	25.7	2.5	33.1	24.9	2.8	29.4	23.6	3.0	27.1	22.9	3.3	24.5	21.9	3.6
	72 (22.2)	39.3	20.5	2.3	38.2	20.3	2.5	36.2	19.6	2.8	30.9	18.2	3.1	28.2	17.6	3.3	25.2	16.4	3.6
1200	57 (13.9)	33.2	33.0	2.3	32.6	32.4	2.5	31.1	30.4	2.8	26.8	26.8	3.1	24.7	24.7	3.3	22.5	22.5	3.6
	62 (16.7)	33.5	31.7	2.3	32.6	32.1	2.5	31.1	30.4	2.8	26.8	26.8	3.1	24.7	24.7	3.3	22.5	22.5	3.6
	63 (17.2)††	33.9	25.5	2.3	33.0	25.7	2.5	31.1	24.8	2.8	26.5	23.3	3.1	24.1	22.8	3.3	21.5	21.5	3.6
	67 (19.4)	36.5	26.6	2.3	35.5	26.7	2.5	33.5	25.8	2.8	29.8	24.5	3.1	27.4	23.8	3.3	24.8	22.7	3.6
	72 (22.2)	39.7	21.3	2.3	38.7	21.1	2.6	36.6	20.3	2.9	31.3	18.9	3.1	28.5	18.3	3.4	25.5	17.1	3.7
1350	57 (13.9)	34.3	34.3	2.3	33.8	33.8	2.6	32.2	32.2	2.8	27.7	27.7	3.1	25.6	25.6	3.4	23.3	23.3	3.7
	62 (16.7)	34.7	34.2	2.3	33.8	33.8	2.6	32.2	32.2	2.8	27.7	27.7	3.1	25.6	25.6	3.4	23.3	23.3	3.7
	63 (17.2)††	35.1	27.3	2.3	34.1	27.4	2.6	32.2	26.5	2.8	27.4	24.9	3.1	25.0	24.4	3.4	22.3	22.3	3.7
	67 (19.4)	37.7	28.4	2.4	36.7	28.6	2.6	34.6	27.6	2.9	30.8	26.2	3.1	28.4	25.4	3.4	25.6	24.3	3.7
	72 (22.2)	41.1	22.8	2.4	40.0	22.6	2.6	37.8	21.7	2.9	32.4	20.2	3.2	29.5	19.6	3.4	26.4	18.2	3.7

See Legend and Notes on page 12

042

EVAPORATOR AIR		CONDENSER ENTERING AIR TEMPERATURES °F (°C)	
-------------------	--	---	--

Cooling Capacities (cont)
048

EVAPORATOR AIR		CONDENSER ENTERING AIR TEMPERATURES °F (°C)																	
CFM	EWB	75 (23.9)			85 (29.4)			95 (35)			105 (40.6)			115 (46.1)			125 (51.7)		
		Capacity MBtuh		Total System KW**	Capacity MBtuh		Total System KW**	Capacity MBtuh		Total System KW**	Capacity MBtuh		Total System KW**	Capacity MBtuh		Total System KW**	Capacity MBtuh		Total System KW**
		Total	Sens‡		Total	Sens‡		Total	Sens‡		Total	Sens‡		Total	Sens‡		Total	Sens‡	
1400	57 (13.9)	45.5	45.5	3.1	44.0	44.0	3.5	41.9	41.9	3.8	36.5	36.5	4.2	33.3	33.3	4.7	28.7	28.7	5.1
	62 (16.7)	47.3	43.5	3.1	45.2	42.5	3.5	43.1	40.2	3.8	37.5	35.7	4.2	34.2	33.6	4.7	29.5	29.0	5.1
	63 (17.2)††	48.2	35.1	3.1	46.1	34.0	3.5	43.5	32.8	3.8	37.4	30.9	4.2	33.7	30.9	4.7	28.5	27.7	5.1
	67 (19.4)	51.9	36.6	3.2	49.5	35.4	3.5	46.7	34.2	3.9	42.1	32.5	4.2	38.3	32.1	4.7	32.7	29.7	5.1
	72 (22.2)	56.5	29.3	3.2	54.0	28.0	3.5	51.1	26.9	3.9	44.2	25.0	4.2	39.9	24.7	4.7	33.7	22.3	5.2
1600	57 (13.9)	47.7	47.1	3.2	46.1	44.5	3.5	43.9	41.7	3.9	38.3	37.1	4.3	34.9	34.9	4.7	30.1	30.1	5.2
	62 (16.7)	48.3	45.2	3.2	46.1	44.1	3.5	44.0	41.7	3.9	38.3	37.1	4.3	34.9	34.9	4.7	30.1	30.1	5.2
	63 (17.2)††	48.8	36.5	3.2	46.6	35.3	3.5	44.0	34.1	3.9	37.9	32.1	4.3	34.1	32.1	4.7	28.8	28.8	5.2
	67 (19.4)	52.5	38.0	3.2	50.1	36.8	3.5	47.3	35.5	3.9	42.5	33.7	4.3	38.8	33.4	4.7	33.1	30.9	5.2
	72 (22.2)	57.2	30.4	3.3	54.6	29.0	3.6	51.7	28.0	4.0	44.7	26.0	4.3	40.3	25.7	4.8	34.1	23.2	5.2
1800	57 (13.9)	49.4	49.4	3.3	47.7	47.5	3.6	45.4	44.6	4.0	39.6	39.6	4.3	36.1	36.1	4.8	31.2	31.2	5.2
	62 (16.7)	50.0	48.8	3.3	47.7	47.1	3.6	45.5	44.6	4.0	39.6	39.6	4.3	36.1	36.1	4.8	31.2	31.2	5.2
	63 (17.2)††	50.5	39.0	3.3	48.2	37.7	3.6	45.5	36.4	4.0	39.2	34.3	4.3	35.3	34.3	4.8	29.8	29.8	5.2
	67 (19.4)	54.3	40.6	3.3	51.9	39.3	3.6	48.9	38.0	4.0	44.0	36.1	4.3	40.1	35.7	4.8	34.2	33.0	5.2
	72 (22.2)	59.2	32.5	3.3	56.5	31.0	3.6	53.5	29.9	4.0	46.2	27.8	4.4	41.7	27.5	4.8	35.3	24.8	5.3

See Legend and Notes on page 12.

060

**System kW is total of indoor and outdoor unit kilowatts.

‡Sensible capacities shown are based on 80°F (27°C) entering air at the indoor coil. For sensible capacities at other than 80°F (27°C), deduct 835 Btuh (245 kW) per 1000 CFM (480 L/S) of indoor coil air for each degree below 80°F (27°C), or add 835 Btuh (245 kW) per 1000 CFM (480 L/S) of indoor coil air per degree above 80°F (27°C).

††At TVA rating indoor condition (75°F edb/63°F ewb). All other indoor air temperatures are at 80°F (27°C) edb.

LEGEND

BF — Bypass Factor

CFM — Cubic Feet per Minute

edb — Entering Dry Bulb

ewb — Entering Wet-Bulb

^hewb — Enthalpy, entering wet bulb

^hlwb — Enthalpy, leaving wet bulb

kW — Total Unit Power Input

SHC — Sensible Heat Capacity (1000 Btuh)

^t = Temperature (°F)

^tedb — Entering Temperature, Dry Bulb (°F)

^tldb — Leaving Temperature, Dry Bulb (°F)

^tlwb — Leaving Temperature, Wet Bulb (°F)

TC — Total Capacity (1000 Btuh) (net)

NOTES:

1. Direct interpolation is permissible. Do not extrapolate.

2. The following formulas may be used:

$$^t\text{ldb} = ^t\text{edb} - \frac{\text{Sensible capacity (Btuh)}}{1.10 \times \text{CFM}}$$

$$^t\text{lwb} = \text{Wet-bulb temperature corresponding to enthalpy air leaving evaporator coil } (^t\text{lwb})$$

$$^h\text{lwb} = ^h\text{ewb} - \frac{\text{total capacity (Btuh)}}{(4.5 \times \text{CFM})}$$


Where: ^hewb = Enthalpy of air entering evaporator coil

The SHC is based on 80°F (26.7°C) edb temperature of air entering indoor coil.

Below 80°F (25.7°C) edb, subtract (corr factor x CFM) from SHC.

Above 80°F (25.7°C) edb, add (corr factor x CFM) from SHC.

Correction Factor = 1.10 x (1 - BF) x (edb - 80)



Filter Pressure Drop (IN. W.C.)

FILTER SIZE in. (mm)	CFM																	
	500	600	700	800	900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200
20X20X1 (508X508X25)	0.05	0.07	0.08	0.10	0.12	0.13	0.14	0.15	—	—	—	—	—	—	—	—	—	—
20X24X1 (508X610X25)	—	—	—	0.08	0.09	0.10	0.11	0.13	0.14	0.15	0.16	—	—	—	—	—	—	—
24X30X1 (610X762X25)	—	—	—	0.04	0.05	0.06	0.07	0.07	0.08	0.09	0.10	—	—	—	—	—	—	—
24X36X1 (610X914X25)	—	—	—	—	—	—	—	0.06	0.07	0.07	0.08	0.09	0.09	0.10	0.11	0.12	0.13	0.14


Accessory Electric Heat Pressure Drop (IN. W.C.)

HEATER kW	CFM							
	800	1000	1200	1400	1600	1800	2000	2200
5-20	0.033	0.037	0.042	0.047	0.052	0.060	0.067	0.075

Wet Coil Air Delivery *

Unit Size	Speed Taps	Tap Color	Air Delivery	External Static Pressure (in. W.C.)									
				0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	1
24	1	BLU	SCFM	893	805	721	672	628	579	530	495	455	414
	2	PNK	SCFM	956	862	772	720	673	620	567	530	457	444
	3	RED†	SCFM	1000	963	917	873	828	783	740	692	636	579
	4	ORN	SCFM	1041	1011	964	920	863	836	791	744	695	643
	5	BLK	SCFM	1182	1131	1105	1060	1025	986	944	906	864	800
30	1	BLU	SCFM	1000	965	923	883	839	800	749	716	660	617
	2	PNK	SCFM	1060	1018	986	946	907	875	830	792	752	695
	3	RED†	SCFM	1171	1135	1096	1062	1031	1000	964	929	894	857
	4	ORN	SCFM	1302	1265	1232	1195	1162	1131	1098	1066	1042	1012
	5	BLK	SCFM	1304	1267	1230	1197	1164	1132	1097	1065	1041	1000
36	1	BLU	SCFM	1226	1153	1106	1062	1015	969	921	848	802	758
	2	PNK	SCFM	1274	1224	1182	1137	1093	1051	1008	959	891	844
	3	RED†	SCFM	1398	1370	1329	1290	1250	1209	1168	1126	1085	1020
	4	ORN	SCFM	1422	1386	1349	1309	1270	1231	1192	1151	1110	1066
	5	BLK	SCFM	1530	1486	1450	1411	1372	1335	1297	1261	1222	1194
42	1	BLU	SCFM	1401	1296	1242	1188	1142	1190	1042	997	921	872
	2	PNK	SCFM										

Typical Field Wiring



KILOWATTS	VOLTS	PHASE	HERTZ	CONTROL VOLTS	STEPS	HEATER AMPS	CIRCUIT BREAKER		
							C.B. # 1	C.B. # 2	C.B. # 3
15.0/20.0	208/240	1	60	24 AC	2	72.1/83.3	50A	60A	60A
CPHEATER132A03				(110070158)					

Single-Phase Accessory Electric Heater Wiring


A190339

Electrical Data

MODEL	NOMINAL V-PH-HZ	VOLTAGE RANGE		COMPRESSOR		OFM	IFM	NOMINAL ELECTRIC HEAT*	POWER SUPPLY		
		MIN	MAX	RLA	LRA	FLA	FLA	kW	FLA	MCA	MOCP†
24	208/230-1-60	197	253	9	63	0.94	2.7	-/-	-/-	14.9	20
								3.8/5	18/20.8	25.9/29.4	30/30
								5.6/7.5	27/31.3	37.1/42.5	40/45
								7.5/10	36.1/41.7	48.5/55.5	50/60
30	208/230-1-60	197	253	12.5	67	0.94	3.9	-/-	-/-	20.4	30
								3.8/5	18/20.8	27.4/30.9	30/35
								5.6/7.5	27/31.3	38.6/44	40/45
								7.5/10	36.1/41.7	50/57	50/60
36	208/230-1-60	197	253	13.5	75	1.5	3.9	-/-	-/-	22.3	35
								3.8/5	18/20.8	27.4/30.9	35/35
								5.6/7.5	27/31.3	38.6/44	40/45
								7.5/10	36.1/41.7	50/57	50/60
42	208/230-1-60	197	253	15.8	96	1.5	3.9	-/-	-/-	25.2	40
								3.8/5	18/20.8	27.4/30.9	40/40
								5.6/7.5	27/31.3	38.6/44	40/45
								7.5/10	36.1/41.7	50/57	50/60
48	208/230-1-60	197	253	19.4	102	1.5	5.1	-/-	-/-	30.9	50
								3.8/5	18/20.8	30.9/32.4	50/50
								5.6/7.5	27/31.3	40.1/45.5	50/50
								7.5/10	36.1/41.7	51.5/58.5	60/60
60	208/230-1-60	197	253	23.3	125	1.9	6.9	-/-	-/-	37.9	60
								3.8/5	18/20.8	37.9/37.9	60/60
								5.6/7.5	27/31.3	42.4/47.8	60/60
								7.5/10	36.1/41.7	53.8/60.8	60/70
								11.3/15	54.1/62.5	76.3/86.8	80/90
								15/20	72.1/83.3	98.8/112.8	100/125

Application Data

Condensate trap — A 2-in. (51 mm) condensate trap must be field supplied.



A08001


Maximum cooling airflow — To minimize the possibility of condensate blow-off from the evaporator, airflow through the units should not exceed 450 CFM/ton.

Minimum cooling airflow — The minimum cooling airflow is 350 CFM/ton.

Minimum cooling operating outdoor air temperature — All standard units have a minimum ambient operating temperature of 40°F (4.4°C). With accessory low ambient temperature kit, units can operate at temperatures down to 0°F (-17.8°C).

Maximum operating outdoor air temperature — Maximum outdoor operating air temperature for cooling is 125°F (51.7°C).

Typical Installation



A10135

Guide Specifications

General

Furnish and install outdoor package, electrically controlled, air conditioner utilizing a reciprocating or scroll compressor for cooling duty. Unit shall discharge supply air horizontally as shown on contract drawings.

Nominal unit electrical characteristics shall be _____ v, _____ ph, 60 Hz. The unit shall be capable of satisfactory operation within voltage limits of _____ v to _____ v. Unit power wiring shall enter unit cabinet at a single location.

Separate power supply shall not be required for electric heat.

Cooling Capacity

Total cooling capacity of the unit shall be _____ Btuh or greater, and sensible capacity shall be _____ Btuh or greater at conditions of _____ CFM indoor air entering unit at _____ F dry bulb, _____ F wet bulb and outdoor entering air of _____ F dry bulb. Total design conditions shall be a minimum of _____ Btuh/Watt. The unit shall be capable of cooling operation down to 40°F (4.4°C) as shipped from the factory.

Cabinet

Unit cabinet shall be constructed of phosphated, bonderized, zinc-coated, prepainted steel. Basepan shall be made of a single-piece non-corrosive, composite material.

Evaporator-fan compartment interior cabinet surfaces shall be insulated with a minimum 1/2-in. (12.7 mm) thick, flexible fiberglass insulation, coated on the air side with aluminum foil.

Cabinet panels shall be easily removable for servicing.

Outdoor coil shall be protected by metal louvered panels.

Compressor

Compressor shall be fully hermetic type with external vibration isolation.

Condenser Section

Condenser fan shall be of the direct-driven propeller type blades, riveted to corrosion-resistant spiders, and shall be dynamically balanced and discharge air vertically upwards.

Condenser coils shall have aluminum-plate fins mechanically bonded to copper tubes with all joints brazed.

Tube sheet openings shall be belled to prevent tube wear.

Evaporator Section

Fan shall be multi-speed with direct drive motor as shown on the equipment drawings.

Fan wheel shall be made from steel, be double-inlet type with forward-curved blades with a corrosion-resistant finish and dynamically balanced.

Evaporator coils shall have aluminum-plate fins mechanically bonded to aluminum tubes with all joints brazed.

Tube sheet openings shall be belled to prevent tube wear.

Motors

Compressor motors shall be of the refrigerant cooled type with line break thermal and current overload protection.

All fan motors shall have permanently lubricated bearings, and inherent automatic reset thermal overload protection.

Condenser fan motor shall be totally enclosed.

Refrigerant System

Refrigerant system shall include fixed orifice or TXV metering system.

Controls

Unit shall be complete with self-contained low voltage control circuit.

Approvals

Unit shall be UL listed as a total package for safety requirements. All wiring shall be in accordance with NEC.

Unit shall be rated in accordance with AHRI Standards 210/240.

Cabinet insulation shall conform to ASHRAE Standard 62.2

Insulation and adhesive shall meet NFPA 90A requirements for flame spread and smoke generation.

Unit shall have a sloped drain pan that conforms to ASHRAE Standard 62.2.

Accessories

Field-installed accessories shall include solid-state compressor short-cycle device, outdoor thermostat, room thermostats, electric heaters with single-point connection, crankcase heater, and low-ambient kit.